



Laboratory Analysis Data

Negaunee/Ishpeming Water Authority Water Treatment Plant

Average Range - Tap Water Analysis Data (January-December)	
Test	Tap
Chlorine Residual (ppm)	0.40 - 0.60
pH	8.10 - 8.20
Temperature (° C)	7.8 (Winter) - 9.0 (Summer)
Color (Units)	0 - 4
Turbidity (NTU)	0.02 - 0.04
Iron (ppm)	0 - 0.02
Manganese (ppm)	0.01 - 0.03
Total Hardness (ppm)	175 – 195
Alkalinity (ppm)	155 – 170
Non- CO ₃ Hardness (ppm)	20 - 25
Calcium as CaCO ₃ (ppm)	126 – 140
Fluoride Conc. (ppm)	0.70
Conductivity	680 – 690
Chloride (ppm)	110 - 130
Sulfate (ppm)	18-25
<u>Operator Comments:</u> All data provided represents the range of your current water from January to December of any given year. We test these numbers daily and are continually looking for ways to improve the quality of water.	